

# STRUCTURAL DESIGN POINT

**Er. R. K. Jaglan**

**B.E (Civil) F.I.V. M.I.E. (INDIA)**

Regd. Structure Engineer (Design), Chartered Engineer

Regd. with HUDA & M.C. Regd. No.15& 3

Regd. Valuer Govt. Of India

Fellow Of Institute of Valuer, New Delhi

Member of Institute of Engineers, Calcutta.

**Building Expert**

Office-Cum-Resi. :

#311, Defence Colony

HISAR (Haryana) - 125001

Mob. 98961-41380 (O)

Mob. 92537-48330 (O)

Mob. 94164-31450 (R)

Ref No. J/25/2017

Dated 11/03/2017

## SAFETY CERTIFICATE OF COLLEGE BUILDING

On the request of Sh. Dinesh Kumar, President, Oxford International College of Education situated at 8km stone, Kusumbhi Mor, Bhiwani (Haryana) to examine and issue a certificate related to structural strength of the said building. I inspected the said building on 11/03/2017.

Sh. Dinesh Kumar, President, Oxford International College of Education situated at 8km stone, Kusumbhi Mor, Bhiwani (Haryana).

The college campus covered 1 Acres land and boundary wall for security purpose.

### Specifications :

The building is load bearing structure with foundation steps footing of 1<sup>st</sup> class bricks masonry. It has a R.C.C. roof, sufficient windows and doors in good condition.

### Observations :

1. Wall do not show any cracks, indicate that there is no settlement of the foundation.
2. The roof do not show any cracks.
3. The structural design of the structural is safe against seismic and wind forces.
4. Floor surface conglomerate and leveled and do not show any dent.
5. No underground moisture was observed / indicate and the structure is free from dampness.
6. The super imposed load do not exceed 0.5 ton per sq. ft.

### Inference:

In view of the facts stated above, I am of the opinion that the building is absolutely safe for college purpose.

Building life will remain for next 99 (Ninety Nine) years.

President  
New Era Education Charitable  
Trust, ASB, New Delhi (India)

Er. R. K. Jaglan  
F.I.V., M.I.E.  
Regd. Structural Engineer  
Registration No. 15 HUDA  
311, Defence Colony  
HISAR (Hr.) M. 9896141380